

Water Quality Profile Groups

Group	Classification
1A	Arsenic ≤ 20 , pH ≤ 8 , Fluoride ≤ 2
1B	Arsenic ≤ 20 , pH > 8 , Fluoride ≤ 2
2A	Arsenic ≤ 20 , pH ≤ 8 , Fluoride > 2
2B	Arsenic ≤ 20 , pH > 8 , Fluoride > 2
3A	Arsenic > 20 , pH ≤ 8 , Fluoride ≤ 2
3B	Arsenic > 20 , pH > 8 , Fluoride ≤ 2
4A	Arsenic > 20 , pH ≤ 8 , Fluoride > 2
4B	Arsenic > 20 , pH > 8 , Fluoride > 2

NOTE: For Silica > 20 mg/L, Chloride > 200 mg/L, Sulfate > 200 mg/L and TDS
Contaminant name added to end of classification group to indicate interference

Example: 1A - Silica; 4A - Chloride

Phosphorus and radiochemical flags to be added after source water data is obtained